

TOWN of WESTON, CONNECTICUT



Incorporated 1787

Town Engineer's Office

April 25, 2018

Weston Conservation Commission
Weston Town Hall
56 Norfield Road
Weston, CT 06883

RECEIVED

APR 25 2018

TOWN OF WESTON
CONSERVATION COMMISSION

Attention: Michiel Zegers, Chairman

Re Weston Dog Park

Mr. Zegers:

Enclosed is a minor adjustment to the Cultec Recharger System that was submitted to your commission on April 19, 2018 proposed for the Weston dog park. The design of the system has not changed. The adjustment includes realigning the cultec trenches more in line with the existing contour grades. The inverts of the system have been improved to insure the highest cultec trench is 12 inches above the restrictive layer. The other two cultec trenches will be higher than 12 inches above the restrictive. An additional construction detail sheet (page 3A) has been provided to clearly define the construction requirements.

As stated above the design of the cultec recharger system has not changed except for the items listed above. Also enclosed is the revised drainage report from WMC engineers reflecting the changes to the cultec system.

A handwritten signature in cursive script that reads "John Conte".

John Conte P.E.